

Building Safety - Undertaking

Category of application : Fresh Affiliation up to Senior Secondary Level

ARJUNAL BHAGORA

I, **ARJUNAL BHAGORA**, Principal of the school **EKLAVYA MODEL RESIDENTIAL SCHOOL** do hereby undertake that the school run/applied under regular category is unable to obtain / renew Building Safety Certificate issued from the competent government authority / the empanelled engineers by Municipal Corporations/Development Authorities/PWD/Roads/Building Department etc. of the concerned area till date of application. The school was last inspected for the building safety on : 14/03/2024

I assure that before starting of the regular school/commencement of session the above safety certificate will be obtained and submitted. In the meanwhile whole responsibility of the safety and security of staff and students will be on undersigned. Therefore, being a regular category school it may be provisionally allowed.

Principal Sign :

Principal Name :

School Address :

Date :

Place :

Seal :

37/11
प्रधानाचार्य 29/4/24

राजकीय एकलव्य मॉडल आवासीय विद्यालय

परखेला-गढ़ी जिला बाँसवाड़ा (राज.)

टी.डी.ओ. कोड - 38367

(अर्जुनलाल भगोरा)

5

भारत सरकार
केन्द्रीय लोक निर्माण विभाग, अजमेर
कार्यालय: सहायक अभियन्ता, सागवाड़ा
ई-मेल: acsagwaracpwd@gmail.com

पत्र सं. 24(EMRS)/स.अ., सागवाड़ा/2023/249

दिनांक- 25/08/23

To,


The Principal,
Eklavya Model Residential School (EMRS)
Garhi Banswara (Raj.).

Subject:- Safety & Security of the School Building at EMRS Garhi, Banswara Rajasthan.

Sir,

With reference to letter under reference on the subject it is certified that the building is visually structurally sound and safe. However the following suggestions may be followed for up keeping the safety of the building.

1. Plantation/Gardening near foundation should be avoided. So that seepage of water may not cause damages to foundation and flooring.
2. At terrace/Chajjas and roofs opening of rain water pipes may be cleared periodically to avoid seepage/Leakage of water through roofs and walls.
3. Cleaning/Sanitizing of toilets and proper disposal of garbage in dustbins must be ensured.
4. This Certificate is valid for One Year from date of issue of this letter.


सहायक अभियन्ता, सागवाड़ा
के.लो.नि.वि., सागवाड़ा

Copy to:

1. श्रीमान् कार्यपालक अभियन्ता के.लो.नि.वि., अजमेर को सूचनाार्थ प्रेषित है।

सहायक अभियन्ता, सागवाड़ा

[- Many Work Hindi Letter Aug 2023]